



# Networked Lighting Control System Technical Requirements

Version NLC5

Draft 2

April 16, 2020

Note: Changes from Version 4.0 are highlighted in yellow. Changes from Draft 1 to Draft 2 are highlighted in blue.

## Schedule of Revisions

Revision No.	Date	Description
1.0	Apr 21, 2016	<ul style="list-style-type: none"> <li>Initial Technical Requirements published.</li> </ul>
1.01	May 7, 2016	<ul style="list-style-type: none"> <li>Clarified that the Technical Requirements are for interior control systems. Systems designed and marketed exclusively for exterior applications are not eligible to be qualified.</li> </ul>
1.02	Feb 24, 2017	<ul style="list-style-type: none"> <li>Clarified that the Technical Requirements do not cover DC or PoE systems.</li> </ul>
2.0	Jun 1, 2017	<ul style="list-style-type: none"> <li>Version 2.0 published, with addition of exterior control systems.</li> </ul>
3.0	Jun 1, 2018	<ul style="list-style-type: none"> <li>Version 3.0 published, with addition of DC/PoE systems, scenes, and multi-year plans for energy monitoring and cybersecurity.</li> </ul>
4.0	Jun 10, 2019	<ul style="list-style-type: none"> <li>Version 4.0 published, with addition of energy monitoring requirement, criteria for cybersecurity certifications, and building management systems capable of networked lighting control.</li> </ul>
5.0	Draft 1	<ul style="list-style-type: none"> <li>Introduction of an interoperability plan that includes the prior energy monitoring (EM) plan as a sub-topic, and aligns EM definition with ASHRAE 90.1-2016. Requires cybersecurity.</li> </ul>

This document defines requirements to be met or reported for lighting control systems listed on the DesignLights Consortium (DLC) Networked Lighting Controls Qualified Products List (QPL).



12 **Contents**

13 Schedule of Revisions ..... 1

14 Scope of Technical Requirements ..... 3

15 Definition of “Required” vs. “Reported” Capabilities ..... 3

16 Additional Requirements (in addition to Tables 1,2,3) ..... 4

17 Multi-Year Plans ..... 5

18 **Interoperability Plan** ..... 5

19 Cybersecurity Plan ..... 10

20 Annual Revisions and Grace Period ..... 13

21 Requirements for Interior Lighting Systems ..... 14

22 Requirements for Exterior Lighting Systems ..... 14

23 Capability and Requirement Definitions ..... 15

24

25

DRAFT

## 26 Scope of Technical Requirements

27 These are requirements for interior and exterior networked lighting control (NLC) systems associated with  
28 commercial and industrial buildings, roadways, and exterior environments. **Note that while the DLC accepts**  
29 **exterior NLC systems, these systems are not addressed comprehensively at present.** NLC systems are defined  
30 for the purposes of these requirements as the combination of sensors, network interfaces, and controllers  
31 that effect lighting changes in luminaires, retrofit kits or lamps. Luminaires, retrofit kits and lamps are qualified  
32 separately by the DLC's [Solid-State Lighting Technical Requirements](#) and [Qualified Products List](#).

33 DC and PoE networked lighting control systems are eligible to be qualified, in conjunction with the [SSL Testing](#)  
34 [and Reporting Requirements for DC and PoE Lamps, Luminaires, and Retrofit Kits](#).

35 Building Management Systems that control networked lighting plus other building systems, such as HVAC, are  
36 eligible to be qualified as NLC systems and listed on the QPL, provided that they meet all of the DLC's  
37 requirements for NLC. Note that the DLC does not claim to qualify any HVAC-specific capabilities of these  
38 systems at this time.

39 Horticultural control systems are not eligible to be qualified at this time.

40 **For future updates of these requirements, the DLC will explore how to recognize (i.e. "Report" but not**  
41 **"Require") support services; and also how to report more comprehensively on the capabilities of exterior NLC**  
42 **systems.**

## 43 Definition of "Required" vs. "Reported" Capabilities

44 The Technical Requirements are built on "Required" and "Reported" system capabilities.

45 **"Required" Capabilities:** Required capabilities shall be available in all systems to be listed on the QPL. Systems  
46 that do not offer these capabilities are not eligible to be listed. A successful application will provide  
47 information on the availability of these capabilities and characteristics. Key information provided by the  
48 manufacturer will be published on the QPL.

49 *Note:* While the DLC requires systems to offer a particular capability, the DLC does not specify whether a  
50 capability must be installed on a project. For instance, while the DLC requires systems to have daylight  
51 harvesting/photocell capability, the DLC does not specify which rooms or luminaires on a project must be  
52 installed with daylight harvesting/photocell capability. Project-specific requirements for rebates and  
53 incentives are determined by individual efficiency programs.

54 **"Reported" Capabilities:** The DLC will report on the presence or absence of, type, and/or characteristics of  
55 each Reported capability for qualified systems. While systems are not required to include these capabilities, a  
56 successful application will provide information on the presence or absence of these capabilities and their  
57 characteristics. Key information provided by the manufacturer will be published on the QPL.

58

## 59 Additional Requirements (in addition to Tables 1,2,3)

60 **“Customer Available Information”**: In order for an applicant to claim a capability listed in Tables 1 and 2, the  
61 manufacturer’s customer literature must specify that the system has the capability, with instructions for how  
62 to configure and/or use this feature.

63 “Customer available” means the documentation is for a finished product available publicly on a website,  
64 and/or included with the product packaging, and/or provided to the customer upon request. It should not be a  
65 document produced for the sole purpose of obtaining DLC qualification without further use for customers. The  
66 DLC reserves the right to accept, reject, or require changes to documentation to satisfy this requirement. Any  
67 documentation provided to the DLC will be used for the purpose of verifying compliance with DLC Technical  
68 Requirements and will not be made available publicly or distributed.

69 The following capabilities from Table 1 and 2 are exempt from this requirement:

- 70 • Continuous Dimming
- 71 • Individual Addressability
- 72 • Luminaire Level Lighting Control (LLLC, integrated)
- 73 • Ease of Implementation
- 74 • Type of User Interface
- 75 • Cybersecurity
- 76 • Control Persistence
- 77 • Interoperability: LS/DR
- 78 • Interoperability: External Systems Integration

79 **Warranty**: The DLC requires a minimum warranty of at least 5 years for all components of the system  
80 addressed by the requirements, with the exception of software, on-premises computer server, and cloud  
81 service. An optional warranty extension to 5 years is acceptable for meeting this requirement; however, the  
82 QPL will identify that an extended warranty must be purchased to meet the requirements.

83 **Commercial Availability and Verification**: All systems must be fully commercially available in the U.S and/or  
84 Canada, able to be purchased, and with complete, final documentation and literature readily available on the  
85 manufacturer’s website before they can be listed. The DLC requires that a qualified system has been installed  
86 and operated successfully in at least one actual field installation at a third party site (not occupied by the  
87 applicant or a lighting rep). The DLC will verify this through a case study and/or a customer reference. The  
88 facility can be of any size where all of the Required Capabilities are functional. Multiple sites may be used; for  
89 instance, occupancy sensing may be installed at one site and daylight harvest at another. If daylight harvest is  
90 not available at a customer’s site, then it can be demonstrated in an installation at a building owned by the  
91 manufacturer, in a live webinar.

92 **System Overview Presentation**: As part of the application review process, the DLC requires a system overview  
93 to be presented via webinar or in-person to the DLC. See the application form for more information. For  
94 annual re-listings of a previously qualified system for which a recording of a prior presentation is available and  
95 the system has not changed extensively, this requirement may be waived or shortened.

96 All requirements documents, including the application form, instructions, and supporting documentation can  
97 be found on the DLC website at <https://www.designlights.org/lighting-controls/qualify-a-system>.

## 99 Multi-Year Plans

100 In order to serve the needs of stakeholders for long term planning, the DLC includes multi-year plans for some  
101 topics and/or requirements. These plans outline a general direction for each topic over the next few years,  
102 subject to refinement through the stakeholder input process. The DLC is working on a multi-year plan for NLC.  
103 The process will involve extensive stakeholder engagement, including virtual and/or in person event(s).

## 104 Interoperability Plan

105 Building systems, including networked lighting control (NLC) systems, increasingly need to cooperate and  
106 communicate with other systems beyond their boundaries to achieve a higher level of operational efficiency  
107 and energy savings. This communication of systems or system components and the ability to act upon the  
108 communicated information is called “interoperability”. Interoperability among building components and  
109 systems is the key enabler for unlocking the benefits from cross-system operation and optimization.

110 Interoperability is recognized in NLC5 as a new “Reported” NLC capability. The new interoperability capability  
111 will provide an umbrella summary to assist in selection of products that support interoperability in relation to  
112 specific use cases. Over time, the DLC plans to recognize additional use cases, and to report the system  
113 capabilities that support these use cases, in order to assist end users in choosing appropriate systems for  
114 various uses. As a starting point, the DLC has identified three use cases for initial priority in reporting  
115 interoperability. These three initial use cases are already addressed under other capabilities: External Systems  
116 Integration, Load Shedding/Demand Response, and Energy Monitoring. Note that the pre-existing energy  
117 monitoring plan has now become part of the broader interoperability plan. Within the interoperability  
118 umbrella, the basic energy monitoring capability is “Required”, while advanced aspects of energy monitoring,  
119 such as data content and format, are “Reported”. Other capabilities are “Reported”, but not “Required”, as  
120 described in the section above ‘Definition of “Required” vs. “Reported” Capabilities’.

## 121 Descriptions and plans for the 3 initial interoperability use cases:

### 122 1. External Systems Integration

123 **Description:** Data from NLC components, such as luminaires, sensors, and controllers, is made  
124 available through an Application Programming Interface (API) and can be utilized by other building  
125 systems to improve their operational efficiencies. Accessing the NLC component data using the API  
126 allows integration with other building systems, including the Heating Ventilation and Air Conditioning  
127 (HVAC) system, energy management system, security system, etc. For example, an HVAC system might  
128 use occupancy data from an NLC system.

129 **Plan:** An example of data about external systems integration that already exists in the DLC database is  
130 occupancy data granularity. Under NLC5, this data will be presented on the QPL as an aspect of  
131 interoperability. The NLC5 application will include additional Reported questions regarding  
132 communications with external systems through APIs and reporting frequency/latency/format. As  
133 applicable standards become available, the DLC will report compliant products.

134

135

136

## 2. Load Shedding/Demand Response (LS/DR)

137

138

139

140

141

142

143

**Description:** *Basic/1-way:* A demand response signal is received by an NLC system, and the energy consumption of the system is reduced in a pre-defined way, on a temporary basis, without manual intervention. *Advanced/2-way:* A control feedback loop and communication is established between a building’s demand response server and a demand control originator (such as a grid operator, energy provider, microgrid, or onsite Distributed Energy Resource), so that the building modifies its real-time energy consumption in response to the originator’s needs, and reports the results to the originator. The NLC participates in this ecosystem as one of the load-responding building systems.

144

145

146

147

148

**Plan:** Examples of data about communication for LS/DR<sup>1</sup> that already exist in the DLC database include power data availability, granularity, and accuracy. The NLC5 application will include additional Reported questions regarding LS/DR, such as availability of the data in Table DR-1 below, and the typical latency of NLC responses. As relevant new standards become available, the DLC will report compliant products.

149

**Table LS/DR-1**

Communication	Inquiry from the demand control originator	NLC response
1-way	Load reduction request (unspecified amount, starting now)	Execute
1-way or 2-way	Load reduction request for a specified amount starting at a specified time for a specified duration	1-way: Execute 2-way: Acknowledge & execute
1-way or 2-way	Cancellation of load reduction	1-way: Execute 2-way: Acknowledge & execute
2-way	Present load status?	Kilowatt (kW)
2-way	Data as interval or status change?	Flag
2-way	Reporting interval	Number of minutes
2-way	Recurring load status update at a specified interval or upon status change	Periodic kW report at a specified interval
2-way	Planned load reduction capacity for a specified future time (peak) and duration (accumulated) period	Kilowatt (kW) – peak Kilowatt-hour (kWh) – accumulation over period

150

151

## 3. Energy Monitoring (EM)

152

153

154

155

156

157

**Description:** Lighting system energy data is reported by the NLC and can be shared electronically (automatically or manually generated email) with authorized entities. For example, utility energy efficiency programs for NLCs can receive the energy data to verify energy savings. The lighting energy data may also be accessed for central display of facility energy end-use status or for a building portfolio management provider to benchmark energy performance. Ideally, the data will use a standardized data model, when available.

<sup>1</sup> For a recent exploration of this topic, see “The Value Proposition for Cost-Effective, Demand Responsive-Enabling, Nonresidential Lighting System Retrofits in California Buildings”, April 2019, Peter Schwartz et al, <https://www.energy.ca.gov/2019publications/CEC-500-2019-041/CEC-500-2019-041.pdf>



158 **Plan:** The basic capability of energy monitoring is “Required”, with an exception for room-based  
159 systems. Data is reported via a .CSV file and/or an API. Methods of energy monitoring may include  
160 automated measurement methods and methods that require manual input of wattage to measure  
161 energy use. As part of the application or re-application process, each product that qualifies for energy  
162 monitoring must provide the DLC with a sample .CSV file or API documentation.

163 **Energy monitoring capability is not required for room-based systems.** A “room-based system” is defined  
164 as follows: A system that is designed to control lighting in a single room or space, and where the control,  
165 configuration, and management of the system is contained within the room or space illuminated by the  
166 system. In order to interact with the system, (for instance, to change any settings or to download any  
167 data), a user must be physically present in, or in close proximity to, the room or space illuminated by the  
168 system.

169 In order for a system to qualify for this exemption, the DLC review process confirms that the product  
170 claims only “Room or Zone” for interior scope as listed on the DLC QPL, and that the system does not  
171 require a gateway internet connection.

172 The basic capability of energy monitoring is loosely aligned with ASHRAE 90.1-2016 Section 8.4.3  
173 “Electrical Energy Monitoring”, as outlined below in Table 3 Row 11.

174 Advanced capabilities of energy monitoring are “Reported”.

175 In the absence of a more detailed applicable standard (beyond ASHRAE 90.1) describing energy data  
176 reports, details about data content in the following tables are “Reported”, not “Required”.

177 Tables EM-1 and EM-2 describe the recommended contents of an energy monitoring data report. The  
178 Online NLC QPL will report which systems offer these contents. This table is derived from the DLC report  
179 “Energy Savings from Networked Lighting Control (NLC) Systems”, 9/21/2017, Appendix A, Tables 8 and 9.  
180 The DLC is participating in the ANSI/NEMA C137 Committee to develop more specific data requirements.

**Table EM-1: Energy Data Reporting Guidelines for .CSV or API; Static Data**

Row	Topic	Data Element	Definition	Note
1.1	Headings	For each field	Each type of data element is identified by a heading.	Text such as “Manufacturer”, “Product”, etc.
1.2	System	NLC Manufacturer	The manufacturer of the NLC system	Text
1.3	System	NLC Product	The name of the NLC system	Text
1.4	Site	Building/Business Type [*Note A]	The main business function in the portion of the building where the NLC system is installed	From ASHRAE 90.1-2016 Table 9.5.1
1.5	Baseline for NLC	Maximum Rated Power with no control strategy enabled	The maximum possible power consumption of the lighting system without any control strategy in effect. If a luminaire retrofit has occurred, this value is equal to the maximum rated power of the new luminaire(s). The spatial granularity matches the energy measurements. For instance, if energy is reported at each luminaire, then the baseline power is reported at each luminaire.	Separate data for interior vs. exterior. Units = kiloWatts
1.6	Energy	Energy Reporting Interval [*Note B]	The frequency an energy measurement is reported (15 minutes or less)	Units = minutes
1.7	Energy	Data method	How is energy interval data calculated?	Text such as “15 minute average from 3 samples spaced 5 minutes apart”

**Table EM-2: Energy Data Reporting Guidelines for .CSV or API; Dynamic Variables**

Row	Topic	Data Element	Definition	Note
2.1	Headings	For each field	Each type of data element is identified by a heading.	Text such as “Unix Time”, “Energy Data kWh”, etc.
2.2	Energy	Timestamp	Date and time of each energy measurement	Unix time or RFC 3339 time
2.3	Energy	Energy Data	The actual energy readings that are recorded for each luminaire or group of luminaires	Units = kWh
2.6	Energy	Confidence Level	The percentage of all possible samples expected to include the true population parameter.	Units = %
2.7	Energy	Nominal Accuracy	% accuracy of the energy data [*Note C]	Text such as “+/-3% or 0.005 kWh, whichever is larger”
2.7	Energy	Record Duration	Months of 15 minute interval data	Units=months



184 **Note A:** For Building/Business Type, ASHRAE Standard 90.1-2016, “Energy Standard for Buildings Except Low-  
185 Rise Residential Buildings” Table 9.5.1 can be freely viewed at [https://www.ashrae.org/technical-](https://www.ashrae.org/technical-resources/standards-and-guidelines/read-only-versions-of-ashrae-standards)  
186 [resources/standards-and-guidelines/read-only-versions-of-ashrae-standards](https://www.ashrae.org/technical-resources/standards-and-guidelines/read-only-versions-of-ashrae-standards), PDF page 155.

187 **Note B:** The need for 15 minute interval data is derived from the IPMVP Options A and B, as typically  
188 implemented by utility programs (International Performance Measurement and Verification Protocol:  
189 Core Concepts and Options for Determining Energy and Water Savings EVO-10000-1.2016, Efficiency  
190 Valuation Organization, evo-world.org.)

191 **Note C:** The accuracy of the energy data as defined by the manufacturer. In the future, the DLC expects to  
192 recognize standards of accuracy as they become available from ANSI C136 and C137.

### 193 **Future Plans for Interoperability**

#### 194 **Additional Use Cases**

195 Additional use cases in the future may involve additional capabilities beyond the three in NLC5.

DRAFT

## 196 Cybersecurity Plan

197 In alignment with the multi-year cybersecurity plan previously published in versions 3.0 and 4.0 of this  
198 document, the DLC is taking the next step to help ensure qualified systems utilize best-practice standards for  
199 cybersecurity. The cybersecurity capability is Required under NLC5. The criteria have been expanded from  
200 NLC V4.0 to offer more options for compliance.

201 Note: While the standards in Table CS-1 and services in Table CS-2 can be applied to NLCs, not all of their  
202 requirements may be relevant for various applications of lighting control systems. Manufacturers and their  
203 certification bodies should review each option to identify the appropriate requirements for each system being  
204 qualified; and customers should select a product based on the risk profile of each project.

## 205 V5 Cybersecurity Program Administration

- 206 • In order to claim the cybersecurity capability, a system must, at the time of qualification, either:
  - 207 a. Have a valid certification for one or more of the specified standards in Table CS-1, or
  - 208 b. Have a valid certification for one or more of the specified services in Table CS-2.
- 209 • The list of applicable standards in Table CS-1 and services in Table CS-2 will be reviewed for each  
210 incremental revision to the Technical Requirements, or annually, whichever comes sooner.
- 211 • Certification in any one of the four categories of Table CS-1 (Process, Components, System, Cloud  
212 Services) is sufficient.
- 213 • Table CS-3 describes how DLC reviewers will confirm compliance.
- 214 • The DLC will confirm cybersecurity certification will be valid for at least 12 months after the time of  
215 application submission. If the certification will expire within a year, the NLC manufacturer will need to  
216 submit a letter of intention of renewal with the application and will need to provide an updated  
217 certificate upon expiration, in compliance with Table CS-2 or CS-3.
- 218 • The DLC will confirm cybersecurity certification once a year in July, whether or not a system updates  
219 data to the next Technical Requirements version. If a certificate has lapsed, a system will need to  
220 recertify in order to remain listed.
- 221 • Some cybersecurity certifications offer different levels of compliance based on risk management. For  
222 instance, some standards offer lower performance requirements for room level systems that cannot  
223 be upgraded to add a permanent internet connection. Therefore, the DLC cybersecurity requirement  
224 applies to all systems—with the understanding that comprehensive systems with many capabilities are  
225 subject to more rigor, compared to simple systems with few capabilities.
- 226 • The grace period for renewals is described below under “Annual Revisions and Grace Period”. For the  
227 new cybersecurity requirement introduced with NLC5, the same grace period is extended to products  
228 that are not previously listed on the DLC QPL.

229



## 230 Criteria for Acceptable Cybersecurity Standards

231 The DLC recognizes the cybersecurity standards listed in Table CS-1 that meet criteria 1-3 below, and the  
232 cybersecurity services listed in Table CS-2 that meet criteria 2-3 below:

- 233 1. Certifiable with a methodology established through either:
  - 234 a. A voluntary consensus process such as ANSI, ISO, IEC, etc.
  - 235 b. A federal agency of the USA or Canada
  - 236 c. A collaborative multi-stakeholder engagement process such as the Cloud Security Alliance
- 237 2. Applies to one or more of the following:
  - 238 a. Product development process lifecycle
  - 239 b. Components/Embedded Devices
  - 240 c. System
  - 241 d. Cloud Services
- 242 3. Includes at least 3 of the following technical content, for (2. b,c,d) above:
  - 243 a. Penetration testing
  - 244 b. Communication robustness testing
  - 245 c. Vulnerability identification testing
  - 246 d. Multiple levels of security

## 247 Definitions

- 248 • **Cybersecurity:** The practice of defending networked systems and data from malicious attacks.
- 249 • **Process:** Standards that address the development process in order to reduce the number of  
250 cybersecurity vulnerabilities that are designed into components, systems, and services, and that  
251 manifest over the product lifecycle.
- 252 • **Components:** Standards that address the cybersecurity of each individual physical end device in a  
253 networked system.
- 254 • **System:** Standards that address the networked system, including aspects such as authentication, data  
255 confidentiality, system integrity, service availability, protocol converters, firewalls, gateways, web  
256 servers, and web services interfaces.
- 257 • **Cloud Services:** Standards for cloud services that address secure integration with services from a  
258 remote cloud computing provider.

## 259 List of Certifications

260 Certifications that meet the criteria are listed in Tables CS-1 and CS-2. Once a certification is on this list, the  
261 DLC does not expect to remove it with less than two years of notice.

## 262 Future Plans

263 The DLC plans to maintain cybersecurity requirements similar to NLC5 for at least two years, with the possible  
264 addition of new standards as they become available, and minor changes in language if needed for clarification.  
265 In the meantime, development efforts will explore the potential for more substantial updates after two or  
266 more years, to keep pace with the fields of cybersecurity and cyber privacy.

267 **Table CS-1: Cybersecurity Standards Recognized by the DLC**

Standard	Process	Components/ Embedded Devices	System	Cloud Services
ANSI/UL 2900-1	y	y		
IEC 62443	62443-4-1	62443-4-2	62443-3-3	
SOC 2	y		y	y
ISO 27001	y			
ISO 27017 (with 27001)				y
FedRAMP				y
CSA STAR				y

268

269 **Table CS-2: Cybersecurity Services Recognized by the DLC**

Service	Proof of Compliance
UL IoT Security Rating (UL 1376)	Copy of certificate or letter from UL
CSA Cybersecurity Verification Program (CVP) (CSA T200)	Copy of certificate or letter from CSA
Intertek Cyber Assured	Copy of certificate or letter from Intertek

270

271 **Table CS-3: Proof of Cybersecurity Standard Compliance**

272 *Renewal is required at least every 3 years in order for a certificate to remain valid.*

Standard	Proof of Compliance
ANSI/UL 2900-1	Certification claim listed on applicant's website, plus a letter or copy of certificate issued by an accredited certification body.
IEC 62443	ISASecure registry of a component, system, or CDO at <a href="https://www.isasecure.org/en-US/End-Users/">https://www.isasecure.org/en-US/End-Users/</a> or Copy of IECEE certificate, or product listed at <a href="https://www.iecee.org/certification/certificates/">https://www.iecee.org/certification/certificates/</a> or Copy of certificate from other accredited agency, such as UL, VDE, DEKRA, etc.
SOC 2	Certification claim listed on applicant's website, plus a letter from 3 <sup>rd</sup> party auditor.
ISO 27001	Copy of an accredited certification from a member of the ANSI-ASQ National Accreditation Board as listed at <a href="http://anabdirectory.remoteauditor.com/">http://anabdirectory.remoteauditor.com/</a>
ISO 27017 (with 27001)	Copy of an accredited certification from a member of the ANSI-ASQ National Accreditation Board as listed at <a href="http://anabdirectory.remoteauditor.com/">http://anabdirectory.remoteauditor.com/</a>
FedRAMP	"Authorized" at <a href="https://marketplace.fedramp.gov/#/products?status=Compliant;FedRAMP%20Ready&amp;sort=productName">https://marketplace.fedramp.gov/#/products?status=Compliant;FedRAMP%20Ready&amp;sort=productName</a>
CSA STAR	"Certification" or "Attestation" at <a href="https://cloudsecurityalliance.org/star/registry/">https://cloudsecurityalliance.org/star/registry/</a>

273

## 274 Annual Revisions and Grace Period

275 The DLC revises the Networked Lighting Controls Technical Requirements annually, with final revisions  
276 completed in early June of each year. The DLC's goal is to display data that either meets the current  
277 specification or the previous year's specification, so that all of the QPL data is less than two years old.

278 **Grace Period Policy:** A listing grace period until April 15 of the following year (for example, April 15, 2021 for  
279 NLC5) will be provided for systems that have been qualified under a previous version of the Technical  
280 Requirements, but do not meet revised requirements. These systems can be relisted once under the previous  
281 version of the Technical Requirements. This will allow a period of 10.5 months to develop an updated or new  
282 system that can be submitted for evaluation according to the most current Technical Requirements.

283 For example, in June 2020, a system that is currently listed under NLC V4.0 (published in June 2019) has two  
284 options to remain listed in the future:

- 285 a. If the system qualifies for NLC5 (published in June 2020), then the data can be updated to NLC5 at any  
286 time until April 15, 2021.
- 287 b. If the system does not qualify for NLC5, then the product can remain listed as NLC4 until October 31,  
288 2021. After that, if the product and data have not been updated to either NLC5 (by April 2021) or NLC6  
289 (by October 2021), then the product will be delisted.

290 Note that in order to use the grace period when a new set of Technical Requirements are published in June  
291 (for instance NLC5 in June 2020), a system would need to be listed under the previous version (in this example,  
292 NLC4).

293 For the new cybersecurity requirement introduced with NLC5, the same grace period will be extended to new  
294 products (products not previously listed on the DLC QPL). New products will use the NLC5 application form  
295 until April 15, 2021. Until April 15, 2021, if they meet all requirements except for the new cybersecurity  
296 requirement, then they will be qualified as NLC4.

297 **Requirements for Interior Lighting Systems**

298 Table 1 provides a summary of “Required” and “Reported” system capabilities for interior lighting systems.

299 **Table 1: “Required” and “Reported” Capabilities for Interior Lighting Systems**

‘Required’ Interior System Capabilities	‘Reported’ Interior System Capabilities
Networking of Luminaires and Devices	Control Persistence
Occupancy Sensing	Scheduling
Daylight Harvesting/Photocell Control	Device Monitoring/Remote Diagnostics
High-End Trim	Type of User Interface
Zoning	Luminaire Level Lighting Control (LLLC, integrated)
Individual Addressability	Personal Control
Continuous Dimming	Load Shedding/Demand Response
Energy Monitoring	Plug Load Control
Cybersecurity	External Systems Integration
	Emergency Lighting
	Color Changing/Tuning
	Ease of Implementation
	Scene Control
	Interoperability

300 **Requirements for Exterior Lighting Systems**

301 Table 2 provides a summary of “Required” and “Reported” system capabilities for exterior lighting systems.

302 **Table 2: “Required” and “Reported” Capabilities for Exterior Lighting Systems**

‘Required’ Exterior System Capabilities	‘Reported’ Exterior System Capabilities
Networking of Luminaires and Devices	Control Persistence
Occupancy Sensing AND/OR Traffic Sensing	Device Monitoring/Remote Diagnostics
Daylight Harvesting/Photocell Control	Type of User Interface
High-End Trim	Luminaire Level Lighting Control (LLLC, integrated)
Zoning	Load Shedding/Demand Response
Individual Addressability	External Systems Integration
Continuous Dimming	Emergency Lighting
Scheduling	Color Changing/Tuning
Energy Monitoring	Ease of Implementation
Cybersecurity	Scene Control
	Interoperability

303

## 304 Capability and Requirement Definitions

305 Table 3 provides the detailed definitions for each capability or technical requirement. This table applies to  
 306 both Interior and Exterior systems, except where noted. Please note that the application form specifies in  
 307 more detail what information the DLC requires from manufacturers for each capability and what information  
 308 will be published on the QPL.

309 Note: Some NLC systems control luminaires and retrofit kits, and some NLC systems control lamps within  
 310 luminaires. The latter systems use a wireless controller integrated inside each lamp. The “luminaires/lamps”  
 311 phrase indicates that a requirement applies to luminaires and retrofit kits if an NLC system controls luminaires  
 312 and retrofit kits; and the requirement applies to lamps if an NLC system controls lamps.

313 **Table 3: Definitions of Capabilities & Requirements**

Row	Capability	Definition
1	Networking of Luminaires and Devices	The capability of individual luminaires/lamps and control devices to exchange digital data with other luminaires/lamps and control devices on the system. This capability is required at the room, space, or area level, but not at the whole building level or beyond (e.g. non-lighting systems, or the internet).
2	Occupancy Sensing	The capability to affect the operation of lighting equipment based upon detecting the presence or absence of people in a space or exterior environment. Exterior systems must include either occupancy sensing or traffic sensing. They may include both, but that is not required.
3	Traffic Sensing	The capability to affect the operation of lighting or other equipment based upon detecting the presence or absence of moving vehicles in an area. Systems may satisfy this requirement through external systems integration as described below in lieu of in-system sensors if another source of data is used for presence or absence detection. Exterior systems must include either occupancy sensing or traffic sensing. They may include both, but that is not required.
4	Daylight Harvesting / Photocell Control	The capability to automatically affect the operation of lighting or other equipment based on the amount of daylight and/or ambient light that is present in a space, area, or exterior environment. This capability is typically called daylight harvesting for interior systems, and photocell control for exterior systems.
5	High-End Trim*	The capability to set the maximum light output to a less-than-maximum state of an individual or group of luminaires/lamps at the time of installation or commissioning. High-end trim must be field reconfigurable. This capability is distinct from automatic compensation for lumen depreciation, which automatically increases output as a system operates over time.  *While the DLC specifically requires “High-end trim”, some manufacturers refer to this capability as “ <b>task tuning</b> ” or “ <b>tuning</b> ” within their system interfaces. Refer to <a href="#">NEMA LSD 64-2014</a> for definitions of lighting controls terminology.

6	Zoning	<p>The capability to group luminaires/lamps and form unique lighting control zones for a control strategy via software-defined means, and not via physical configuration of mechanical or electrical installation details (e.g. wiring).</p> <p><i>Interior:</i> Zoning is required for occupancy sensing, high-end trim, and daylight harvesting control strategies except for systems that feature luminaire level lighting control (LLLC) capabilities as defined in these requirements under “Reported Capabilities”, in which case zoning is only required for occupancy sensing and high-end trim control strategies.</p> <p><i>Exterior:</i> Zoning is required for high-end trim.</p>
7	Individual Addressability	<p>The ability to uniquely identify and/or address each individual luminaire/lamp, sensor, controller, and user interface device in the lighting system, allowing for configuration and re-configuration of devices and control zones independent of electrical circuiting.</p>
8	Continuous Dimming	<p>The capability of a control system to provide control with sufficient resolution in output (100+ steps) to support light level changes perceived as smooth (as opposed to step dimming with a small number of discrete light levels).</p>
9	Control Persistence	<p>The capability of a networked lighting control system’s lowest-level (“edge device”) luminaire/lamp controllers to execute three energy saving strategies (occupancy sensing, daylight harvesting, and high-end trim) at a room-level, or finer, resolution in the absence of communications with the next higher networked element in the system’s topology.</p>
10	Scheduling	<p>The capability to automatically affect the operation of lighting equipment based on time of day. Scheduling capability is reported for interior systems and required for exterior systems. Exterior systems are required to have time-based scheduling, and "astronomical" scheduling functionality for sunrise and sunset programming, based on geographical location and time of year.</p>



11	Energy Monitoring	<p>The capability of a system to report the energy consumption of a luminaire/lamp and/or a group of luminaires/lamps.</p> <ul style="list-style-type: none"> <li>• Individual luminaire/lamp monitoring as well as energy monitoring on dedicated lighting circuits is acceptable.</li> <li>• The method by which the system implements this capability must be clearly described, including whether the system provides automated energy measurement or relies on numerical manual input during system setup for accurate measurement (such as inputting the wattage of each luminaire/lamp in a project).</li> <li>• Reference consists of one or both of: <ul style="list-style-type: none"> <li>○ Sample .CSV file with documentation</li> <li>○ API documentation</li> </ul> </li> <li>• The basic, required capability of energy monitoring is aligned with ASHRAE 90.1-2016 Section 8.4.3. as follows: <ul style="list-style-type: none"> <li>○ Energy use by interior lighting (if applicable), exterior lighting (if applicable) and receptacle circuits (if monitored by the NLC) can be monitored independently.</li> <li>○ For buildings with tenants, the data for each tenant space can be reported to each tenant.</li> <li>○ The lighting system energy use can be recorded at least once every 15 minutes and reported at least hourly, daily, monthly, and annually.</li> <li>○ Energy use data can be transmitted to a building control system (if present) and graphically displayed.</li> <li>○ Data can be stored for a minimum of 24 months.</li> </ul> </li> <li>• Energy monitoring is not required for room-based systems. In order for room-based systems to claim the optional energy monitoring capability: <ul style="list-style-type: none"> <li>○ Energy data can be retrieved by a user in the room when required - hourly, daily, monthly or yearly.</li> <li>○ Energy data can be retrieved in the form of CSV file or API.</li> </ul> </li> <li>• In order for a system to qualify for this exemption, the DLC review process will confirm that the product claims only “Room or Zone” for interior scope as listed on the DLC QPL.</li> </ul>
12	Device Monitoring / Remote Diagnostics	<p>The capability to monitor, diagnose, and report operational performance including system and/or component failures.</p>
13	Type of User Interface	<p>The type of interface provided by the control system for users to read and adjust control system settings during system start-up, commissioning, and/or ongoing operation.</p>

14	Luminaire Level Lighting Control (LLLC, integrated)	<p>The capability to have a networked occupancy sensor and ambient light sensor installed for each luminaire or kit, and directly integrated or embedded into the form factor during the luminaire or kit manufacturing process.</p> <p>In addition to these required integrated components, LLLC systems must have control persistence capability as described in this document.</p> <p>To demonstrate commercial availability of the integrated component options, at least one family, luminaire or kit with integrated control must be verified by the DLC. Manufacturers may choose whether or not to list this information publicly on the QPL.</p>
15	Personal Control	<p>The capability for individual users to adjust to their personal preferences, via networked means, the illuminated environment of a light fixture or group of light fixtures in a specific task area. The publicly available information must clearly describe a control interface for use by a single individual who does not have access to system-wide settings.</p> <p>A wireless dimmer switch may only be considered a personal control interface if product documentation:</p> <ul style="list-style-type: none"> <li>• shows that the physical configuration is suitable for workstation use (i.e. a small, self-contained unit without any external wiring, suitable for use as a handheld remote control), and</li> <li>• describes configuration for personal control within a larger area.</li> </ul> <p>A software-based interface may only be considered personal control if product documentation:</p> <ul style="list-style-type: none"> <li>• shows it provides a specific interface intended for personal control by an individual user within a subsection of a larger space, and that</li> <li>• the interface only allows access to personal control functions for the light fixtures in the specific areas being controlled (i.e. each occupant can control their own area, but not their neighbors' areas).</li> </ul>
16	Load Shedding/ Demand Response	<p>The capability to reduce the energy consumption of a lighting system, in a pre-defined way, on a temporary basis, in response to a demand response signal <b>without manual intervention</b>. The method by which the system implements this capability <b>(managed by NLC and/or BMS)</b> must be clearly described in the publicly available reference(s). <b>The method for pre-defining the system behavior for temporary load reduction must be accessible through a user interface. The data the NLC can receive and interpret from other networked systems must include at least a signal that can be used for purposes such as LS/DR.</b></p>
17	Plug Load Control	<p>The capability to control the power delivered to receptacles through scheduling or occupancy sensing. The method by which the system implements this capability must be clearly described in the publicly available reference(s).</p>

18	External Systems Integration (e.g. BMS, EMS, HVAC, Lighting, API, Cloud)	<p>The capability to exchange data with other networked systems such as building or energy management systems (BMS/EMS), heating ventilation and air conditioning (HVAC) systems, or other lighting and building systems via BACnet, Modbus, LonWorks or other open protocols, application program interface (API) or other methods. In order to claim this “Reported” capability, the data available from the NLC for exchange with other networked systems must include occupancy status at the zone, space, or area level and energy data at the zone-, circuit- or system-level. The data the NLC can receive and interpret from other networked systems must be digital, that can be used for purposes such as scene control, zones, groups, areas, regions, and/or presets. The method, including formats and languages, by which the system implements this capability must be clearly described in the publicly available reference(s).</p>
19	Emergency Lighting	<p>Publicly available documentation illustrating how a system’s luminaires connect with an emergency power source.</p> <p>The QPL will provide the URL(s) for online documentation provided by manufacturers for system designers to refer to. This documentation will identify wiring diagrams, required components, and/or application guides needed to understand design considerations for integrating the system into an emergency lighting system.</p>
20	Cybersecurity	<p>A cybersecurity certification that meets the DLC criteria. The current standards are shown in Table CS-1 and listed here:</p> <ul style="list-style-type: none"> <li>• ANSI/UL 2900-1</li> <li>• IEC 62443</li> <li>• SOC 2</li> <li>• ISO 27001</li> <li>• ISO 27017 (with 27001)</li> <li>• FedRAMP</li> <li>• CSA STAR</li> </ul> <p>The current services are shown in Table CS-2 and listed here:</p> <ul style="list-style-type: none"> <li>• UL IoT Security Rating (UL 1376)</li> <li>• CSA Cybersecurity Verification Program (CVP) (CSA T200)</li> <li>• Intertek Cyber Assured</li> </ul> <p>Documentation requirements to demonstrate certification are shown in Tables CS-2 and CS-3.</p>
21	Color Changing / Tuning	<p>The capability to alter the output and color of tunable white and/or variable color output luminaires via a dedicated control interface(s). To demonstrate compliance with this capability, the interface(s) must be clearly described in the product literature and allow for at least two CCT settings. These settings may be described in terms of CCT, such as 3000K or 5000K, or simple descriptive terms for the desired setting such as 'Night' or 'Day'. The product literature must also specify installation and configuration requirements to implement this functionality.</p>
22	Ease of Implementation	<p>The QPL will identify the most typical responsible party and their required level of training to start-up and configure the system to the extent that all required capabilities are functioning. Documentation is not required.</p>

23	Scenes	The capability of a system to provide two or more pre-programmed light level settings for a group or multiple groups of luminaires to suit multiple activities in a space, and allow for recall of these settings via a switch, control device, or signal from a BMS or API.
24	Interoperability	The capability of a system or component to communicate data to/from another system or component in a published, repeatable and non-proprietary way, such as a published API. Data sent from an NLC is documented such that others can receive, interpret, and use the data accurately and reliably. This also includes the network protocol requirements, messaging, and related functionality. This capability consists of aspects of other NLC capabilities: currently External Systems Integration, Load Shedding/Demand Response, and Energy Monitoring. Additional capabilities may be included under this umbrella in the future.

314

DRAFT